



Harnett County Emergency Services

Office of the Fire Marshal

PO Box 370

Lillington, NC 27546

(910) – 893 – 7580

Date:

Time:

Occupancy:

Fuel Tank(s) Installation

On the above date and time, a Fuel Tank(s) Installation witnessed at the above location revealed no violations of the N.C. State Fire Code. Piping and Dispenser Tests will need to be conducted by our office once the fuel piping has been installed. Please call our office to schedule these appointments.

Contractor Installing Fuel Tank(s):

Number of Tanks:		AGST	UGST	
#1 Contents	Vol	UL#	Mfg	Air/Vacuum
#2 Contents	Vol	UL#	Mfg	Air/Vacuum
#3 Contents	Vol	UL#	Mfg	Air/Vacuum
#4 Contents	Vol	UL#	Mfg	Air/Vacuum

Notes:

Thank you for your cooperation.

Inspector

The Harnett County Fire Marshal's Division is committed to providing our community with a professional fire and life safety program through comprehensive fire protection plan reviews, informative occupancy inspections, effective fire and life safety code enforcement, and definitive fire origin and cause investigations in order to reduce the loss of life and property of the citizens of Harnett County. We will strive to maintain an unmatched level of professionalism and support to our community.