

November 18, 2024

**ADDENDUM NO. 1
TO THE
BID DOCUMENTS
FOR
HARNETT COUNTY – DUNN-ERWIN C&D LANDFILL EXPANSION**

BID ISSUE DATE: OCTOBER 2024

To All Plan Holders:

The following revisions, additions, and clarifications are hereby made part of the Bid Documents for the above-referenced project and shall be considered in the preparation of all Bids and the execution of all work. Bidders shall acknowledge receipt of the Addendum in the appropriate space on the Bid Sheet and Contract Terms Acceptance Form. Failure to do so may result in your Bid being considered non-responsive.

I. PRE-BID MEETING SUMMARY

Please find **attached** a copy of a summary of the pre-bid meeting, which was held Wednesday November 13, 2024.

END OF ADDENDUM

Submitted by,
SMITH GARDNER, INC.

DocuSigned by:
Pieter Scheer
5B6B31996A674D7...

Pieter K. Scheer, P.E.
Senior Engineer
pieter@smithgardnerinc.com




11/18/2024

Attachment: Pre-Bid Meeting Summary

This page intentionally left blank.

MEMORANDUM

Date:	November 18, 2024
To:	Pre-Bid Meeting Attendees
From:	Pieter K. Scheer, P.E. Smith Gardner, Inc.  5B6B31996A674D7...
RE:	Harnett County – Dunn-Erwin C&D Landfill Expansion Pre-Bid Meeting Summary – November 13, 2024

A pre-bid meeting was held at the project site on November 13, 2024 at 1:00 p.m. The meeting ended at approximately 1:45 p.m. after a tour of the project site.

Attendees: (See Attached List)

Overview:

After introductions, Mr. Scheer provided an overview of the project as follows:

- Bid Date is December 12 – 2:00 p.m. at County Purchasing Department. This is an informal bid so there will be no formal opening.
- Reference the County’s Bid Invitation for Bid Submittal Information.
- Project consists of the construction of a lateral expansion of the County’s C&D landfill.
- Borrow is available on-site within the project area.
- Each bidder is to provide a schedule for performing the work.
- The project is expected to be awarded in January.

Review of Drawing Set:

Mr. Scheer reviewed the drawing set with the attendees generally as follows:

- **Drawing S1 - Existing Conditions**

Note the following:

- North is oriented to the left.
- The location of the work is on the western and southern sides of the active Area 2 C&D landfill unit, which is unlined.

- **Drawing S2 - Area 2 Expansion Subgrade Grading and Drainage Plan**

Note the following:

- There are two areas for expansion of Area 2. One on the west side and a larger one on the south side.
 - There are diversion and drainage channels to be installed on the north side of the project area.
 - The project areas drain to one of two existing sediment basins (Basin A on the west side of Area 2 and Basin No. 4 on the south side).
 - Excess excavation is to be stockpiled in the designated stockpile area.
 - The soil in the upper 2.0 feet of the landfill subgrade (area inside top of berms) is to be classified as SM, SC, ML, MH, CL, or CH. If soil is too sandy, based on CQA testing to be performed by Smith Gardner and Geotechnologies, it will need to be overexcavated and backfilled with appropriate soils. If necessary, the County will supply suitable soils from another site borrow area if soils from excess excavation are not suitable.
- **Drawings EC1 – EC2 - Erosion and Sedimentation Control (E&SC) Details**
 - **Drawings NCG01 and NCG02 - NCDEQ Standard Requirements**

General Project Information:

- **Coordination:**
 - The Contractor will need to coordinate his activities with the County to not obstruct existing operations.
 - Mr. Beane noted that the County intends to adjust the routes for landfill traffic during the project to avoid impacts to active Contractor work area(s).
- **Safety:**
 - The Contractor will be responsible for safety at the site and is expected to have a safety plan for their operations.
- **Surveying:**
 - The Contractor will be responsible for surveying and layout in order to complete the work.
 - As the project nears completion, the Contractor is to coordinate with Smith Gardner who will perform the record survey of the landfill subgrade.

- **Security:**
 - The Contractor will be responsible for site security and is expected to coordinate with the County when work is performed after landfill operating hours to minimize the potential for public access.
 - The landfill gate must remain closed/locked after facility operating hours.

- **Other Items:**
 - S+G has available drawing files for Drawing S2 in AutoCAD format *(provided to meeting attendees via email on 11/18)*. Please contact us if you have questions, difficulty accessing, etc.
 - Water is available from the creek which runs through the site. An existing access road crosses the creek to the south of the existing Area 1 landfill unit.
 - Contact the landfill (910-814-6148) for coordinating site visits.

Attachment: Pre-Bid Meeting Attendees

**PRE-BID MEETING
ATTENDEES**

NAME	COMPANY/AGENCY	PHONE	EMAIL
Pieter Scheer	Smith Gardner, Inc.	(919) 828-0577 x123 (Office) (919) 815-9377 (Cell)	pieter@smithgardnerinc.com
Robert Dukes	Shamrock	336-207-4009	bdukes@shamrockconstruction.com
Alvin Cagle	Triangle Grading & Paving	336-584-1745	sbass@tgandp.com
Troy Lee	Lorman Inc.	919 820 2367	TroyLee@lormaninc.com
Bryant Lockamy	Lockamy's Grading Inc	919-639-4672 919-524-3354	lockamysgrading@gmail.com
Chad Beane	Harnett County	910-986-4376	cbeane@harnett.org